

MEGHALAYA NON-CONVENTIONAL AND RURAL ENERGY DEVELOPMENT AGENCY,

Near bsf camp mawpat, Shillong7930012.
Phone : 0364 2537343/ Fax No.0364 2537611
Email : mnreda.dir@gmail.com :: www.mnreda.gov.in

No. MNREDA/1658/2015/ 176

Dated: Shillong, the 2nd May, 2016.

CORRIGENDUM

The following corrections in the items under Technical Specification appearing in this Agency's advertisement No.MNREDA/1658/2015, dated 12.04.2016 which were subsequently modified by a corrigendum notified under No.MNREDA/1658/2015/125, dated 26.4.2016 are now finally corrected as follows :-

A. SPV Home Lighting System:

SL.No.	Item	As appeared last	Now corrected
1.	SPV Module (s)		
i)	Wattage to be used	75W	200Wp
2.	BATTERY :		
i)	Type of Battery	Lithium Ion Battery/Tubular Gel/	Lithium Ion Battery
ii)	Capacity	12V/40 Ah	12V/52 Ah
8.	DC fan	1x12V	1x12W (Table fan, three speed blade regulator, made of acrylic plastic blades)
9.	Solar Charger i)Mobile charging point ii)TV point	1x20A	1x20W (For Mobile & TV) i)Mobile charging point ii)TV point

B. SPV STREET LIGHTING SYSTEM :

Sl.No.	Item	As appeared last	Now corrected
1.	Electronics :		
iii)	Light output	➤ 500 lumens	➤ 700 lumens
xxxiii)	Minimum power at Vmax	75W	30 Wp
2.	SPV Module :		
i)	Wattage should be	75W	30 Wp
3.	Battery:		
ii)	Type of battery	Lithium Ion battery/TubularGel/VRLA	Lithium Ion Battery

Member Secretary-cum-Director,

MNREDA

Memo No. MNREDA/1658/2016/176-A,

Dated Shillong, the 2nd May, 2016

Copy to :- (1) The Commissioner & Secretary to the Government of Meghalaya, Power Department.

(2) The State Informatics Officer, NIC Shillong with a request to upload the above corrigendum in the website viz: www.mnreda.gov.in by 03.05.2016 positively as the last date of submission of tender documents is 06.05.2016.

Member Secretary-cum-Director,

MNREDA